



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00630

OWNER'S NAME: DK PROFESSIONAL

DATE: 3/22/2017

TYPE: Slab plumbing

TIME STARTED: 11:08 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12068-0007

1. Underslab DWV on Stack - Ok
2. NOTE: Strip Footings dug - no rebar
3. NOTE: Slab Insulation not installed

INSTRUCTIONS:

NEXT INSPECTION: Slab Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506