



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00630

OWNER'S NAME: DK PROFESSIONAL C

DATE: 5/17/2017

TYPE: Insulation

TIME STARTED: 11:14 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12068-0007

1. Corrections Ok
2. Exterior Wall Insulation - Batt w/ vapor barrier
3. Floor Insulation - Batt
4. Rafter Insulation - Batt
5. NOTE: Stair Framing not complete - Verify @ Final
6. NOTE: Contractor to install draftstop @ cover with GWB
7. NOTE: Contractor to use PVA primer - Verify @ Final

INSTRUCTIONS: Ok to cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506