



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00630

OWNER'S NAME: DK PROFESSIONAL C

DATE: 6/28/2017

TYPE: Final

TIME STARTED: 2:59 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-12068-0007

1. Depth Of Trench Verified.
2. Mylar Burial Tape Installed.
3. NOTE: Piping Wiull Be Installed and On Test at Time Of Tank Placement Inspect ion.

INSTRUCTIONS: OK to Backfill

NEXT INSPECTION: Tank Placement

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506