



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00638

OWNER'S NAME: HUNTER

DATE: 10/24/2016

TYPE: Footings

TIME STARTED: 10:47 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-16-34020-0016

1. Setbacks Ok
2. Verify 10" footing depth, per dwgs, is maintained prior to pouring

**INSTRUCTIONS:** Revise form depth as needed to maintain 10" prior to pour/Once complete Ok to pour

**NEXT INSPECTION:** Foundation Walls

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506