



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00651

OWNER'S NAME: TALISMAN

DATE: 6/6/2017

TYPE: Final

TIME STARTED: 1:45 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-19056-0006

1. Hot Water Not Complete.
2. Mechanical Exhaust Not Complete.
3. Energy Work Sheet Not Onsite For Energy Verification.
4. Blower Door Test Not Onsite.
5. Drywall Required in Mechanical for Fire Protection of Floors and Stairs.
6. Exposed Insulation and Visqueen in Mechanical Room.
7. Crawl Access Not Insulated.
8. Fire Sprinkler Final Not Complete. (Head in Mechanical Closet Not Trimmed.)
9. Fireplace Not Functioning.

**INSTRUCTIONS:** Make Corrections Above. Call for ReInspection When Ready.

**NEXT INSPECTION:** Final Re Inspect.

**RE-INSPECTION FEE DUE?**



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506