## **INSPECTION REPORT**

PERMIT NUMBER:	BP-16-00667	OWNER'S NAME:	KRENGEL
DATE:	6/23/2017	TYPE:	Exterior shear
TIME STARTED:	9:36 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-14-36051-0003		
Exterior shear     Install clips at	ok 20" top plate to blocking per scho	edule	
INSTRUCTIONS: O	k to cover.		
NEXT INSPECTION.			
RE-INSPECTION FEE DUE? VES \$  IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  ADDRESS: iessica.contratto @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694  http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			