



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00675

OWNER'S NAME: KONO

DATE: 11/10/2016

TYPE: Footings

TIME STARTED: 12:16 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19050-0038

1. Setbacks per Suncadia
2. Footing "E" @ NW corner required to be 1' deep
3. Footing "D" @ entry to be 15" deep
4. Footing "D" right of entry to have (4) #5 EW
5. Footing "C" to be 15" deep (clouded on dwg)
6. Continuous footing @ garage to have (2) #5 per 1/S3.1
7. Typical verticals are to be 18" OC per details 10 & 6/S3.1

INSTRUCTIONS: Complete above corrections/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506