



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00675

OWNER'S NAME: KONO

DATE: 5/12/2017

TYPE: Gas piping

TIME STARTED: 1:25 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19050-0038

1. Corrections not complete - Engineer Ltr not on site
2. Fire pit Gas @ 30#/15 mins - Ok

INSTRUCTIONS: Ok to backfill/Verify corrections @ Insulation

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506