



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00676

OWNER'S NAME: TRAILSIDE HOMES

DATE: 11/22/2016

TYPE: Footings

TIME STARTED: 11:05 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-13050-0004

1. Setbacks per Suncadia
2. House footings ok
3. Garage missing 2 point load footings. See on approved set of plans

INSTRUCTIONS: Contractor will take photos of grids in footings before pour. Size can be verified at walls. Ok to pour

NEXT INSPECTION: Walls

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506