



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00676

OWNER'S NAME: TRAILSIDE HOMES

DATE: 3/14/2017

TYPE: Exterior shear

TIME STARTED: 1:40 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-13050-0004

1. Tighten up exterior nailing - in progress
2. Provide straps @ window wall per 10/6 - in progress
3. HD's to be installed on (2) full height studs - clouded on dwgs
4. Window in downstairs shower not tempered - clouded on dwg
5. Window in kitchen not tempered - clouded on dwgs

INSTRUCTIONS: Complete nailing and straps in progress/Once complete Ok to cover exterior/Verify HD's and SG windows next inspection

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506