



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00694

OWNER'S NAME: MDJ CONTRACTORS I

DATE: 1/11/2017

TYPE: Mechanical and plumbir

TIME STARTED: 9:58 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-18-07060-0008

1. HD's installed - Ok
2. Gas @ 34#/15 mins - Ok
3. Complete exhaust fan terminations
4. HVAC supply and return Ok
5. Plumbing not on test

INSTRUCTIONS: Place plumbing on test

NEXT INSPECTION: Plumbing

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506