## **INSPECTION REPORT**

PERMIT NUMBER:	BP-16-00694	OWNER'S NAME:	MDJ CONTRACTORS
DATE:	1/12/2017	TYPE:	Framing
TIME STARTED:	10:28 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	17-18-07060-0008		
<ol> <li>DWV @ 6#/15 mins - Ok</li> <li>Supply @ 80#/15 mins - Ok</li> <li>Plumbing RI Ok</li> <li>Install Timberlock or H1 per dwg</li> <li>Complete joist blocking for 2nd Flr BWP (clouded 3 locations)</li> <li>Fireplace RI Ok</li> <li>Trusses Ok</li> </ol>			
INSTRUCTIONS: Complete above/Verify @ Insulation			
NEXT INSPECTION: Insulation			
RE-INSPECTION FEE DUE? NO YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  ADDRESS: <u>iustin.bennett</u> @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506