



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00701

OWNER'S NAME: COWEN

DATE: 3/17/2017

TYPE: Final

TIME STARTED: 12:22 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 22-11-15051-0015

1. Boiler R&R installation Ok
2. Boiler operation Ok
3. Mechanical Final Ok

INSTRUCTIONS: Mechanical Final Ok

NEXT INSPECTION: N/A

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506