



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00711

OWNER'S NAME: ANDERSON

DATE: 5/30/2017

TYPE: Shearwalls

TIME STARTED: 11:38 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29051-0056

1. All nailing on shear panels to be 10d nails
2. Address strap under window next to garage

INSTRUCTIONS: Possible engineer approval for existing nailing or fix to be addressed
Shear was not inspected at this point

NEXT INSPECTION: Re-inspect

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506