



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00711

OWNER'S NAME: ANDERSON

DATE: 6/15/2017

TYPE: Exterior shear

TIME STARTED: 2:19 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29051-0056

1. Engineer letter on site - Ok
2. Exterior Shear Ok
3. Interior Shear Ok
4. Interior HD missing (1) location - clouded on dwgs

INSTRUCTIONS: Ok to cover exterior

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506