



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00711

OWNER'S NAME: ANDERSON

DATE: 7/11/2017

TYPE: Mechanical

TIME STARTED: 2:10 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29051-0056

1. Gas @ 20#/15 mins - Ok
2. HD installed per shear correction
3. Range hood make-up air installed
4. Outside air installed
5. Mechanical Ok

INSTRUCTIONS:

NEXT INSPECTION: Plumbing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506