



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00757

OWNER'S NAME: DAVALT

DATE: 6/30/2017

TYPE: Plumbing

TIME STARTED: 12:39 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-06055-0005

1. Slab DWV @ 5#/15 mins - Ok
2. Supply @! 70#/15 mins - Ok
3. Slab RI Ok

INSTRUCTIONS: Ok to backfill

NEXT INSPECTION: Plumbing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506