



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00759

OWNER'S NAME: FORGEY

DATE: 7/14/2017

TYPE: Mechanical and plumbir

TIME STARTED: 2:37 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-34063-0002

1. Plumbing not on test
2. Exhaust duct ok
3. Supply/return duct ok

INSTRUCTIONS: Call for framing and re-inspect plumbing.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506