



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00759

OWNER'S NAME: FORGEY

DATE: 7/17/2017

TYPE: Framing

TIME STARTED: 3:57 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-34063-0002

1. Plumbing Corrections OK.
2. Trusses OK.
3. Framing OK.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506