



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00761

OWNER'S NAME: MILLS

DATE: 4/4/2017

TYPE: Footings

TIME STARTED: 3:26 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-16-31020-0011

1. Piers on Soth Side to Be Excavated and Poured Later. NOT INSPECTED.
2. Setbacks OK.
3. Footings OK.

INSTRUCTIONS: OK to Pour Footings.

NEXT INSPECTION: Foundation Walls

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506