



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00771

OWNER'S NAME: CROFFUT

DATE: 6/21/2017

TYPE: Slab plumbing

TIME STARTED: 12:58 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-16-26052-0001

1. Underslab DWV on Stack - Ok
2. Slab Insulation Ok
3. NOTE: Vent not terminated through roof

INSTRUCTIONS: Ok to backfill

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506