



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00771

OWNER'S NAME: CROFFUT

DATE: 7/6/2017

TYPE: Framing

TIME STARTED: 2:19 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-16-26052-0001

1. NOTE: Plumbing and Mechanical Inspections are Required to be Completed Prior to Calling for Framing Inspection.
2. NOTE: Plumbing and Mechanical Inspections Performed at this Time.
3. Plumbing Rough In of Vents Not Complete.
4. Plumbing Pressure Tests OK. DWV at 5#/15min OK. Supply at 60#/15min. OK.
5. Trusses OK.
6. Framing OK.

INSTRUCTIONS: Make Corrections Visible at Insulation Inspection. OK to Insulate.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506