



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00771

OWNER'S NAME: CROFFUT

DATE: 7/10/2017

TYPE: Insulation

TIME STARTED: 10:52 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-16-26052-0001

1. Correction not complete - Plumbing Vent not terminated to exterior
2. Insulation Ok
3. Wall Insulation - Batt w/ vapor barrier
4. Rafter Insulation - Batt
5. NOTE: Permit and Dwgs not on site

INSTRUCTIONS: Complete vent termination to exterior/Once complete Ok to cover Interior/Verify vent @ Final

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506