INSPECTION REPORT

MOI ECHOIT KEI OKI			
PERMIT NUMBER:	BP-16-00775	OWNER'S NAME:	TALISMAN
DATE:	5/19/2017	TYPE:	Shearwalls
TIME STARTED:	2:54 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-15-19056-0073		
 Tighten up nailing @ exterior P1-3 Complete straps @ rear window per 4/D2 Install HD in (1) location @ rear door - strap in door Tighten up nailing @ interior P1-3 - red crayon Complete HD installation (4) Complete CS strap FIr to FIr per A5 Interior shear @ Master and Bedroom 2 to be seen after cover 			
INSTRUCTIONS: Complete above/Once complete Ok to cover exterior			
NEXT INSPECTION: Plumb/Mech			
RE-INSPECTION FEE	DUE? V NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
ADDRESS: <u>iustin.bennett</u> @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506