



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00778

OWNER'S NAME: TALISMAN VILLAGE

DATE: 6/23/2017

TYPE: Mechanical and plumbir

TIME STARTED: 1:58 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-19056-0076

1. NOTE: Interior Shear Corrections Not Complete - Verify HD's and Straps @ Framing
2. Plumbing Rough In OK. DWV on Stack Test. OK.
3. NOTE: Plumbing Supply Not On Test. Must Be Verified at Next Inspection.
4. Fireplace Rough In Not Complete.
5. Mechanical Rough In of Mini Splits OK.
6. Mechanical Exhaust Not Complete Throughout

INSTRUCTIONS: Complete Above

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506