



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00788

OWNER'S NAME: HART

DATE: 5/4/2017

TYPE: Shearwalls

TIME STARTED: 4:26 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-20-29000-0001

1. Exterior Nailing Ok
2. (8) STHDRJ not installed

INSTRUCTIONS: Install HD's as indicated

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506