



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-17-00025

OWNER'S NAME: MCDONALD

DATE: 6/8/2017

TYPE: Rough-in plumbing

TIME STARTED: 2:16 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-19-06093-0002

1. Plumbing Rough In OK.
2. DWV at 5#/15min. OK.
3. Supply at 100#/15min. OK.

INSTRUCTIONS: Call for Mechanical When Ready

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506