



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-17-00047

OWNER'S NAME: WILSON

DATE: 6/13/2017

TYPE: Framing

TIME STARTED: 1:29 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-18-27071-0128

1. Exterior Shear Ok
2. Framing Ok
3. Trusses Ok
4. NOTE: Fireplace not installed

INSTRUCTIONS: Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506