



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-17-00091

OWNER'S NAME: MDJ CONTRACTORS

DATE: 6/8/2017

TYPE: Mechanical and plumbir

TIME STARTED: 2:18 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-07060-0006

1. Plumbing Rough In OK. Supply and Drain Not On Test.
2. Mechanical Not Complete.

INSTRUCTIONS: Cal for Mech Frame when ready.

NEXT INSPECTION: Mech Frame

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506