



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-17-00139

OWNER'S NAME: MORTON

DATE: 6/22/2017

TYPE: Shearwalls

TIME STARTED: 11:04 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-17-04051-0007

1. Exterior Shear Ok
2. Portal Framing Ok
3. Straps Ok

INSTRUCTIONS: Ok to cover exterior

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506