INSPECTION REPORT

IIIOI ECITORI NEI ORI			
PERMIT NUMBER:	BP-17-00223	OWNER'S NAME:	BIENFANG
DATE:	7/11/2017	TYPE:	Foundation walls
TIME STARTED:	1:23 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-15-29050-0053		
 Foundation Walls Ok Interior and Exterior piers Ok Install (2) #4 continues in strip footing @ trash room and HD (21) Foundation Vents installed - Ok 			
INSTRUCTIONS: Complete above/Once complete Ok to pour			
NEXT INSPECTION: Floor Framing			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
ADDRESS: <u>iustin.bennett</u> @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506