



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FO-14-00044

OWNER'S NAME: SAVIO

DATE: 8/26/2014

TYPE: Footings

TIME STARTED: 2:12 PM

INSPECTOR: Amber Green

MAP NUMBER: 21-14-16052-0002

	1. Spread footings required to be 12" thick per plans.
	2. Structure must be a minimum of 25 from the front property line.

INSTRUCTIONS: Complete #1. String property line for setback inspection. Re-call inspection.

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506