## **INSPECTION REPORT**

IIII LCIIOII ILLI OIII			
PERMIT NUMBER:	FO-17-00005	OWNER'S NAME:	WOODRIDGE
DATE:	5/17/2017	TYPE:	Foundation walls
TIME STARTED:	1:11 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-15-29051-0036		
<ol> <li>Foundation Walls Ok</li> <li>Exterior Piers Ok</li> <li>Interior Piers Ok</li> <li>NOTE: Confirm w/ Engineer that 7' of unbalanced fill is acceptable @ NW corne</li> </ol>			
INSTRUCTIONS: Ok to pour/Provide engineer approval  NEXT INSPECTION: Floor Framing			
Thou training			
RE-INSPECTION FEE		DAID DDIOD TO SCUT	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION  QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
	ADDRESS:	iustin.bennett @	

**INSPECTION REQUEST LINE: 509-962-7694** 

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506