## **INSPECTION REPORT**

PERMIT NUMBER: FO-17-00016 OWNER'S NAME: CANCELOSI

DATE:	6/12/2017	TYPE:	Footings
TIME STARTED:	4:06 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-14-24050-0506		
1. (2) 36x36x10 piers not installed in footing - footing is poured			
INSTRUCTIONS: Complete corrections above/Verify at Foundation Walls			
INSTRUCTIONS.	omplete corrections above verify	at i odiladion wa	
NEXT INSPECTION:	Foundation Walls		
RE-INSPECTION FEE			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			
http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			