



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: K-98-08066

OWNER'S NAME: MCCANN

DATE: 9/2/2015

TYPE: Final

TIME STARTED: 1:21 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-16-30053-0001

1. numerous bath fans unhooked from terminations in attic and/or broke apart
2. penetrations in fire separation are not allowed unless 1 hr. fire rated (speakers, combustion air inlet)
3. door between garage and residence to be self-closing, 1 and 3/8" thick solid wood or 20 min. fire rated
4. whole house fan in laundry room to be on intermittent timer
5. bollard for impact protection needed in front of water heater/furnace area
6. water heater needs seismic strapping
7. verify access and sewer approval through building department
8. post address at road

**INSTRUCTIONS:** complete above, call for re-inspection

**NEXT INSPECTION:** re-inspection

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto@co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506