

**From:** [Aaron Lowe](#)  
**To:** [Jamey Ayling](#)  
**Cc:** [Dan Young](#)  
**Subject:** Fowler Creek Camp Area  
**Date:** Friday, July 19, 2024 4:20:28 PM

---

**CAUTION:** This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Good afternoon Jamey, here are KCFD7 inputs for the Fowler Creek Project. Have a great weekend!

- Road width and construction needs to meet code
  - This includes USFS roads
  - Roads should be maintained (certified?)
  - Interior roads and turnarounds to meet Fire and WUI Codes
- Water source needs to meet code with each construction phase
  - Water Storage
  - Pressure
  - GPM
  - Fire Pump
- Fire Management Plan
  - Evacuation routes identified to those in attendance
  - Trailers are not to be towed during evacuation
  - Method for 24-hour seven day a week plan to open evacuation route gate
    - Southern Exit on FS4517
  - Trailer Sites properly marked individually

Aaron Lowe  
Fire Chief  
Kittitas County Fire District #7  
31 Firehouse Road  
Cle Elum, WA 98922

[alowe@kcf7.com](mailto:alowe@kcf7.com)

Cell: 509 899-0226

THIS COMMUNICATION MAY BE SUBJECT TO PUBLIC DISCLOSURE LAWS OF THE STATE OF WASHINGTON (RCW.42.56).

ELECTRONIC PRIVACY NOTICE: This e-mail, and any attachments, contains information that is, or may be, covered by electronic communications privacy laws and is confidential and proprietary in nature. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. Instead, please reply to the sender that you have received this communication in error and then immediately delete it. Thank you in advance for your cooperation.