



KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Fire Marshal (509) 962-7000 Deputy Fire Marshal (509) 962-7657

November 28, 2022

To: Whom It May Concern
Re: RU-22-00005 Kostanich

Regarding the proposal above, the KCFMO does not see a reason why approval should not be granted. The KCFMO also does not see any additional fire, nor emergency risk by granting approval, nor by constructing the proposed single-family residence.

If the review of this application does grant approval, the proposed structure shall be subject to KCFMO Wildland Urban Interface Code evaluations/inspections, which may indicate that automatic fire sprinklers shall be installed, as well as, creating a defensible space which may also require the removal of trees, dead/downed litter, and other natural vegetation.

The applicant should take into consideration the effect of building a defensible space will have on the stream buffer zone and as it pertains to the Reasonable Use Criteria. This is not a full description of applicable fire code and the KCFMO reserves the right to apply requirements to this project as new developments or concerns arise.

Thank you for your time.

Deputy Fire Marshal,
Joseph A Dietzel