



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: March 11, 2025
SUBJECT: SPF-25-00001 Lewis

ACCESS	<ol style="list-style-type: none">1. A KRD Crossing license may be required prior to the issuance of an access permit.2. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application. (JS)
ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)
SURVEY	There are no necessary changes to the provided map. (JT) OF NOTE Lot closures have not been reviewed as the provided documents were unreadable.
TRANSPORTATION CONCURRENCY	No comments. (JS)
FLOOD	No comments. (SC)
WATER MITIGATION/ METERING	No additional comments- water mitigation requirements have been met. (SC)
AIRPORT	No comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.