



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: November 7, 2024
SUBJECT: AU-24-00006 Firl

ACCESS	<ol style="list-style-type: none">1. Parcel 956834 has an approved access permit (AC-23-00008) on file with Public Works. As proposed, the existing access will be used to serve this ADU.2. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.3. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards Title 12.4. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application. (JS)
ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)
SURVEY	There are no survey comments regarding this application. (JT)
TRANSPORTATION CONCURRENCY	No comments. (JS)
FLOOD	No comments. (SC)
WATER MITIGATION/ METERING	Per KCC 13.35.027 water mitigation and metering will be required for the ADU because it is a new use of ground water. Parcel #956834 is not located within the OTC service area for the Kittitas County Water Bank. Please call the Kittitas County Public Works Water Resources program at (509)962-7523 to discuss mitigation options and metering requirements. (SC)
AIRPORT	No comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.