

KITTITAS COUNTYDEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff

FROM: Public Works Plan Review Team

DATE: July 5, 2024

SUBJECT: BL-24-00012 Blue Jay Land Company

ACCESS	1. An approved access permit shall be required from the Kittitas County	
ACCESS	·	
	Department of Public Works prior to creating any new driveway access	
	or altering an existing access.	
	Road certification will be required with the issuance of access permits for Double O Road.	
	3. Maintenance of driveway approaches shall be the responsibility of the	
	owner whose property they serve. The County will not maintain accesses.	
	 Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road 	
	Standards.	
	In addition to the above-mentioned conditions, all applicable Kittitas County	
	Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application.	
ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)	
SURVEY	As the application does not contain a survey map, comments are reserved until final. (KAH)	
TRANSPORTATION CONCURRENCY	A concurrency evaluation and determination shall be required for all development applications in which the proposed development is projected to have an impact upon the transportation corridor or intersection. Developments generating 41 or fewer daily trips are exempt from TIA and concurrency evaluation requirements. (KCC 12.04.02.020) (KAH)	
FLOOD	No comments. (SC)	

F	
Page 2	

WATER	No comments. (SC)
MITIGATION/	
METERING	
AIRPORT	No comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.