

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Office (509) 962-7657 Fax (509) 962-7682

May 2, 2016

Jeff Watson Staff Planner Community Development Services 411 N. Ruby Street, Suite 2 Ellensburg, WA 98926

Re: Webb (CU-16-00001)

Dear Mr. Watson:

Upon review of the above mentioned land use action, I have the following comments/requirements;

- A turn-around shall be provided for fire department access.
- Fire extinguishers shall be located appropriately. I can assist with this prior to occupancy.
- A fire and life safety inspection shall be conducted prior to occupancy.
- All development, design and construction shall comply with Kittitas County Code, Kittitas County Zoning and the most current version of the International Fire & Building Codes.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at (509) 962-7000.

Sincerely,

Josh Hink Interim Fire Marshal