

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle)

- Construction
 - Decommission *ORIGINAL CONSTRUCTION Notice*
- 159820 of Intent Number

CURRENT Notice of Intent No. W170941

Unique Ecology Well ID Tag No. AKL 764

Water Right Permit No. _____

Property Owner Name Jeff Link

Well Street Address Lot 18 Big creek

City Kittitas County: Kittitas 19

Location SW 1/4 - 1/4 Sec 21 T20 N14 EWM circle or one WWM

Lat/Long: (s,r still REQUIRED) Lat Deg _____ Lat-Min/Sec _____ Long Deg _____ Long Min/Sec _____

Tax Parcel No. 2014210500018

PROPOSED USE: Domestic Industrial Municipal
 DeWater Irrigation Test Well Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____
 New Well Reconditioned Method: Dug Bored Driven
 Deepened Cable Rotary Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 6.5 ft.
Depth of completed well 65 ft.

CONSTRUCTION DETAILS
Casing Welded 6 " Diam. from 3 ft. to 6.5 ft.
Installed: Liner installed _____ " Diam. from _____ ft. to _____ ft.
 Threaded _____ " Diam. from _____ ft. to _____ ft.

Perforations: Yes No
Type of perforator used _____
SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: Yes No K-Pac Location _____
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot Size _____ from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: Yes No Size of gravel/sand _____
Materials placed from _____ ft. to _____ ft.

Surface Seal: Yes No To what depth? 20 ft
Materials used in seal Bentonite
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
Static level 25 ft. below top of well Date: 11-9-04
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.


Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Date of test _____
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Airtest 35 gal./min. with stem set at 60 ft. for 2 1/2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

CONSTRUCTION OR DECOMMISSION PROCEDURE
Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered.
(USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
<u>top soil</u>	<u>0</u>	<u>2</u>
<u>multi color gravel</u>	<u>2</u>	<u>18</u>
<u>gravel + sand brown</u>	<u>18</u>	<u>45</u>
<u>clay down + yellow</u>	<u>45</u>	<u>65</u>



Start Date 11-9-04 Completed Date 11-9-04

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.
 Driller Engineer Trainee Name (Print) M.K. Morcfield Drilling Company Water man Well Drill
Driller/Engineer/Trainee Signature _____ Address PO Box 246
Driller or Trainee License No. 2361 City, State, Zip: Selah WA 98942

If trainee, licensed driller's _____
Signature and License no. _____

Contractor's Registration No. WATERW002071 Date 123104
Ecology is an Equal Opportunity Employer. ECY 050-1-20 (Rev 4/01)