

From: [Adam Osbekoff](#)
To: [Chace Pedersen](#)
Subject: RE: PF-24-00002 KCFD7 Training Tower - Notice of Application
Date: Tuesday, March 12, 2024 2:45:15 PM

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Hello Chase

The Snoqualmie Tribe [Tribe] is a federally recognized sovereign Indian Tribe. We were signatory to the Treaty of Point Elliott of 1855; we reserved certain rights and privileges and ceded certain lands to the United States. As a signatory to the Treaty of Point Elliot, the Tribe specifically reserved among other things, the right to fish at usual and accustomed areas and the “privilege of hunting and gathering roots and berries on open and unclaimed lands” off-reservation throughout the modern-day state of Washington.

Thank you for the opportunity to review and comment. Based on the information provided and our understanding of the project and its APE, we would recommend an archeological review performed for this project. This is in an area the Snoqualmie Tribe considers culturally significant and has a high probability to have unknown archaeological deposits. If any archaeological work is performed, we request notification. An IDP should not be used in lieu of archeological investigation. Cultural and archaeological resources are non-renewable and are best discovered prior to ground disturbance.

Thank you.

Adam Osbekoff
Cultural Resource Compliance Manager
adam@snoqualmietribe.us
C: 425.753.0388
9416 384th Ave SE
PO BOX 969
Snoqualmie Washington 98065

From: Chace Pedersen <chace.pedersen@co.kittitas.wa.us>
Sent: Tuesday, March 12, 2024 9:24 AM
To: Dan Young <dan.young@co.kittitas.wa.us>; Marvin Douvier (SH) <marvin.douvier.sh@co.kittitas.wa.us>; Kim Dawson <kim.dawson@co.kittitas.wa.us>;

From: [Mau, Russell E \(DOH\)](#)
To: [Chace Pedersen](#)
Cc: [Holly Erdman](#); [Smits, Brenda M \(DOH\)](#); [DOH EPH DW ERO ADMIN](#)
Subject: RE: PF-24-00002 KCFD7 Training Tower - Notice of Application; Kittitas County Water District #5, 427047, Kittitas County
Date: Tuesday, March 12, 2024 9:30:42 AM

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Chace:

The applicant's narrative indicates no water for the additional structure, and that is fine and dandy.

The Department of Health Office of Drinking Water has no other comments or concerns.

Thanks,

Russell E. Mau, PhD, PE

Regional Engineer

Office of Drinking Water

Washington State Department of Health

Russell.Mau@doh.wa.gov

www.doh.wa.gov | 509-329-2116

From: Chace Pedersen <chace.pedersen@co.kittitas.wa.us>

Sent: Tuesday, March 12, 2024 9:24 AM

To: Dan Young <dan.young@co.kittitas.wa.us>; Marvin Douvier (SH)

<marvin.douvier.sh@co.kittitas.wa.us>; Kim Dawson <kim.dawson@co.kittitas.wa.us>;

adminstaff@kittcom.org; storch@kittcom.org; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Laura

Kukes <laura.kukes@co.kittitas.wa.us>; Public Health Inspectors

<PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti

Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Candie

Leader <candie.leader@co.kittitas.wa.us>; Jackie Sharp <jackie.sharp@co.kittitas.wa.us>; Jeremy

Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <steph.mifflin@co.kittitas.wa.us>; Haley

Mercer <haley.mercer@co.kittitas.wa.us>; Christy Garcia <christine.garcia@co.kittitas.wa.us>;

ken.edwards@kittitaspud.com; DAHP SEPA <sepa@dahp.wa.gov>; enviroreview@yakama.com;

Corrine Camuso <Corrine_Camuso@Yakama.com>; Jessica Lally <Jessica_Lally@Yakama.com>;

noah_oliver@yakama.com; Casey Barney <Casey_Barney@Yakama.com>;

From: [Ken Edwards](#)
To: [Chace Pedersen](#)
Subject: RE: PF-24-00002 KCFD7 Training Tower - Notice of Application
Date: Friday, March 15, 2024 10:28:38 AM
Attachments: [image001.png](#)

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Chace,

KCPUD does not have facilities in the area of this project.

Thanks,

Ken Edwards
Engineering Manager
PUD #1 of Kittitas County
1400 Vantage Highway
Ellensburg, WA 98926
Phone: 509-933-7200 Ext 818
Ken.Edwards@KittitasPUD.com



From: Chace Pedersen <chace.pedersen@co.kittitas.wa.us>
Sent: Tuesday, March 12, 2024 9:24 AM
To: Dan Young <dan.young@co.kittitas.wa.us>; Marvin Douvier (SH) <marvin.douvier.sh@co.kittitas.wa.us>; Kim Dawson <kim.dawson@co.kittitas.wa.us>; adminstaff@kittcom.org; storch@kittcom.org; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Laura Kukes <laura.kukes@co.kittitas.wa.us>; Public Health Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Candie Leader <candie.leader@co.kittitas.wa.us>; Jackie Sharp <jackie.sharp@co.kittitas.wa.us>; Jeremy Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <steph.mifflin@co.kittitas.wa.us>; Haley Mercer <haley.mercer@co.kittitas.wa.us>; Christy Garcia <christine.garcia@co.kittitas.wa.us>; Ken Edwards <Ken.Edwards@kittitaspud.com>; DAHP SEPA (DAHP) <sepa@dahp.wa.gov>; enviroreview@yakama.com; Corrine Camuso <Corrine_Camuso@Yakama.com>; Jessica Lally <Jessica_Lally@Yakama.com>; noah_oliver@yakama.com; Casey Barney <Casey_Barney@Yakama.com>; kozj@yakamafish-nsn.gov; matj@yakamafish-nsn.gov; guy.moura@colvilletribes.com; sam.rushing@colvilletribes.com; Connor Armi <connor.armi.hsy@colvilletribes.com>; darnell.sam.adm@colvilletribes.com; john.sirois.adm@colvilletribes.com; milton.davis.adm@colvilletribes.com;

From: [WSDOT Aviation Land Use Inquiries and Application Submittals](#)
To: [Chace Pedersen](#)
Subject: RE: [EXTERNAL] PF-24-00002 KCFD7 Training Tower - Notice of Application
Date: Monday, March 18, 2024 10:03:12 AM

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Hi M Pedersen,

WSDOT Aviation Division reviewed the provided documentation on 03/18/2024. We have no comments.

Enjoy the weather!

David Ison, PhD | Aviation Planner
Emerging Aviation Technologies & Land Use Compatibility
Washington State Department of Transportation
david.ison@wsdot.wa.gov C: 360-890-5258

From: Chace Pedersen <chace.pedersen@co.kittitas.wa.us>
Sent: Tuesday, March 12, 2024 9:24 AM
To: Dan Young <dan.young@co.kittitas.wa.us>; Marvin Douvier (SH) <marvin.douvier.sh@co.kittitas.wa.us>; Kim Dawson <kim.dawson@co.kittitas.wa.us>; adminstaff@kittcom.org; storch@kittcom.org; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Laura Kukes <laura.kukes@co.kittitas.wa.us>; Public Health Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Candie Leader <candie.leader@co.kittitas.wa.us>; Jackie Sharp <jackie.sharp@co.kittitas.wa.us>; Jeremy Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <steph.mifflin@co.kittitas.wa.us>; Haley Mercer <haley.mercer@co.kittitas.wa.us>; Christy Garcia <christine.garcia@co.kittitas.wa.us>; ken.edwards@kittitaspud.com; DAHP SEPA (DAHP) <sepa@dahp.wa.gov>; enviroreview@yakama.com; Corrine Camuso <Corrine_Camuso@Yakama.com>; Jessica Lally <Jessica_Lally@Yakama.com>; noah_oliver@yakama.com; Casey Barney <Casey_Barney@Yakama.com>; kozj@yakamafish-nsn.gov; Matthews, Jim <matj@yakamafish-nsn.gov>; guy.moura@colvilletribes.com; sam.rushing@colvilletribes.com; Connor Armi <connor.armi.hsy@colvilletribes.com>; darnell.sam.adm@colvilletribes.com; john.sirois.adm@colvilletribes.com; milton.davis.adm@colvilletribes.com; steve@snoqualmietribe.us; dahp@snoqualmietribe.us; Adam Osbekoff <adam@snoqualmietribe.us>; Mau, Russell E (DOH) <Russell.Mau@doh.wa.gov>;

From: [Connor Armi](#)
To: [Chace Pedersen](#)
Cc: [Guy Moura](#); [Hanson, Sydney \(DAHP\)](#)
Subject: Re: PF-24-00002 KCFD7 Training Tower - Notice of Application
Date: Tuesday, March 19, 2024 9:13:49 AM

CAUTION: This email originated from outside the Kittitas County network. Do not click links, open attachments, fulfill requests, or follow guidance unless you recognize the sender and have verified the content is safe.

Hello Chace,

This consult is in reference to PF-24-00002 *KCFD7 Training Tower*. It is unclear as to the extent of the ground disturbing activities that will result from the construction of this building.

This undertaking is located within the CCT Traditional Territories. We request any undertakings, particularly those involving ground disturbing activities, to have an IDP in place prior to implementation.

The proposed project lies within the traditional territory of the Wenatchi Tribe, 1 of the 12 constituent tribes of the Confederated Tribes of the Colville Reservation (CTCR), which is governed by the Colville Business Council (CBC). The CBC has delegated to the Tribal Historic Preservation Officer (THPO) the responsibility of representing the CTCR with regard to cultural resources management issues throughout the traditional territories of all of the constituent tribes under Resolution 1996-29. This area includes parts of eastern Washington, northeastern Oregon, the Palus territory in Idaho, and south-central British Columbia.

As ground disturbing activities are to be conducted, such as but not limited to the installation of a septic system or the scraping of a driveway, a cultural resource surface survey and sub-surface testing of the area in and directly around the proposed ground disturbance are recommended as a surface observation will not be an accurate assessment of the existent potential for subsurface cultural deposits. This test should be to the terminal depth of the septic installation to ensure the totality of the presence or absence of cultural material.

There are known cultural resources of precontact and historic significance nearby and this particular plat is considered Very High Risk for an inadvertent discovery according to the DAHP predictive model. This parcel has not been previously surveyed and a preliminary archaeological investigation would be prudent.

CCT requests a cultural resource survey prior to the implementation of ground disturbing activities and that during implementation that there be an inadvertent discovery plan or (IDP) in place to ensure compliance with all Section 106 and relevant cultural resource laws both federally and to the state of Washington.

Thank you for consulting with the Colville Confederated Tribes History and Archaeology Program.

On behalf of Guy Moura, Tribal Historic Preservation Officer.

Sincerely,

Connor Armi | **Archaeologist Senior MA, RPA**
History/Archaeology Program
Confederated Tribes of the Colville Reservation

PO Box 150 | Nespalem, WA 99155
d: 509-634-2690 | c: 509-631-1131
connor.armi.hsy@colvilletribes.com

On Tue, Mar 12, 2024 at 9:23 AM Chace Pedersen <chace.pedersen@co.kittitas.wa.us> wrote:

Good morning,

CDS is requesting comment on the following Public Facilities application: PF-24-00002 KCFD7 Training Tower. Links to the file materials can be found below. The comment period will end **March 27, 2024, at 5pm**. CDS will assume your agency does not wish to provide comment if not received by this date. Please let me know if you have any issues accessing the materials.

Internal Link: PF-24-00002 KCFD7 Training Tower

External Link: [PF-24-00002 KCFD7 Training Tower](#)

If the links above do not work, please go to the CDS website at:

<https://www.co.kittitas.wa.us/cds/land-use/default.aspx> and navigate to “Public Facilities”, “View Active Applications”, and then the project file number “PF-24-00002 KCFD7 Training Tower”.

Thank you,

Chace Pedersen

Planner I

Kittitas County Community Development Services

411 N. Ruby Street, Ste 2

Ellensburg, WA 98926

Office: (509) 962-7637

From: [Public Health Inspectors](#)
To: [Chace Pedersen](#)
Subject: RE: PF-24-00002 KCFD7 Training Tower - Notice of Application
Date: Friday, March 22, 2024 2:44:05 PM

Chace,

This project does not have any water or sewer proposed for the training tower. Public health has no comment or concerns that need to be addressed.

Thank you,

Holly Erdman

From: Chace Pedersen <chace.pedersen@co.kittitas.wa.us>
Sent: Tuesday, March 12, 2024 9:24 AM
To: Dan Young <dan.young@co.kittitas.wa.us>; Marvin Douvier (SH) <marvin.douvier.sh@co.kittitas.wa.us>; Kim Dawson <kim.dawson@co.kittitas.wa.us>; adminstaff@kittcom.org; storch@kittcom.org; Julie Kjorsvik <julie.kjorsvik@co.kittitas.wa.us>; Laura Kukes <laura.kukes@co.kittitas.wa.us>; Public Health Inspectors <PublicHealthInspectors@co.kittitas.wa.us>; Lisa Lawrence <lisa.lawrence@co.kittitas.wa.us>; Patti Stacey <patti.stacey@co.kittitas.wa.us>; Kelee Hodges <kelee.hodges.pw@co.kittitas.wa.us>; Candie Leader <candie.leader@co.kittitas.wa.us>; Jackie Sharp <jackie.sharp@co.kittitas.wa.us>; Jeremy Larson <jeremy.larson@co.kittitas.wa.us>; Steph Mifflin <steph.mifflin@co.kittitas.wa.us>; Haley Mercer <haley.mercer@co.kittitas.wa.us>; Christy Garcia <christine.garcia@co.kittitas.wa.us>; ken.edwards@kittitaspud.com; DAHP SEPA (DAHP) <sepa@dahp.wa.gov>; enviroreview@yakama.com; Corrine Camuso <Corrine_Camuso@Yakama.com>; Jessica Lally <Jessica_Lally@Yakama.com>; noah_oliver@yakama.com; Casey Barney <Casey_Barney@Yakama.com>; kozj@yakamafish-nsn.gov; matj@yakamafish-nsn.gov; guy.moura@colvilletribes.com; sam.rushing@colvilletribes.com; Connor Armi <connor.armi.hsy@colvilletribes.com>; darnell.sam.adm@colvilletribes.com; john.sirois.adm@colvilletribes.com; milton.davis.adm@colvilletribes.com; steve@snoqualmietribe.us; dahp@snoqualmietribe.us; Adam Osbekoff <adam@snoqualmietribe.us>; Mau, Russell E (DOH) <Russell.Mau@DOH.WA.GOV>; separegister@ecy.wa.gov; tebu461@ecy.wa.gov; lowh461@ECY.WA.GOV; FormerOrchards@ecy.wa.gov; wendy.neet@ecy.wa.gov; ECY RE CRO SEPA Coordinator <crosepa@ecy.wa.gov>; Anderson, Ryan (ECY) <rand461@ECY.WA.GOV>; Torrey, Elizabeth M (DFW) <Elizabeth.Torrey@dfw.wa.gov>; Downes, Scott G (DFW) <Scott.Downes@dfw.wa.gov>; Nelson, Jennifer L (DFW) <Jennifer.Nelson@dfw.wa.gov>; rivers@dnr.wa.gov; brenda.young@dnr.wa.gov; luke.warthen@dnr.wa.gov; SEPACENTER@dnr.wa.gov; MARTIN.MAUNEY@dnr.wa.gov; amanda.moody@dnr.wa.gov; Hendrix, Leah D <lhendrix@usbr.gov>; ken.graham@parks.wa.gov; Larned, Kimberly - FS, WA <kimberly.larned@usda.gov>; Deborah.j.knaub@usace.army.mil; jena.e.n.churchill@usace.army.mil; Jacob.Prilucik@wsdot.wa.gov; SCPlanning@wsdot.wa.gov; AviationLandUse@wsdot.wa.gov; CMOlcese@bpa.gov; Connell,Valorie L (BPA) - TERR-PASCO <VLConnell@bpa.gov>; rightofway@pse.com; dylan.marcus@pse.com; jorgenja@cwu.edu;



KITTITAS COUNTY DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: March 27th, 2024
SUBJECT: PF-24-00002 KCFD7 Training Tower

ACCESS	Public Works does not have access comments for this proposal. (JS)
ENGINEERING	Except as exempted in Section KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CC)
SURVEY	There are no survey comments regarding this application. (JT)
TRANSPORTATION CONCURRENCY	A transportation concurrency management application may be required. Please provide traffic scoping letter for courtesy screening and determination. (KAH)
FLOOD	Parcel #952894 is not located in the FEMA identified special flood hazard area (100-year floodplain). A floodplain development permit is not required. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No comments. (JS)