



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: September 14th, 2022
SUBJECT: SX-22-00017 Klaus

ACCESS	
ENGINEERING	No comments
SURVEY	
FLOOD	The proposed project is within the FEMA-identified special flood hazard area. A floodplain development permit is required, and the project will need to meet the standards identified in KCC 14.08. To ensure that the gazebo does not encroach into the FEMA designated floodway, the floodway boundary will need to be marked on site by a licensed surveyor and the gazebo will need to be located outside the floodway boundary.
WATER MITIGATION/METERING	