

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff

FROM: Public Works Plan Review Team

DATE: December 2nd, 2022

SUBJECT: SX-22-00024 Rocky Coulee

ENGINEERING	No comments (jf)
FLOOD	Please note that the FEMA Flood Insurance Rate Maps have been updated and that the current regulatory maps have an effective date of 9/24/2021. Proposed replacement and repair of the post and rail fence and campsite posts are determined to be outside the regulatory floodplain. A floodplain development permit is not required for the proposed activity.
WATER MITIGATION/METERING	No comment (AT)