



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: August 7, 2024
SUBJECT: SX-24-00017 Balkovetz

ENGINEERING	Except as exempted in KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080). (CP)
FLOOD	The proposed RV pad is located within the FEMA identified special flood hazard area (100-year floodplain). All activities within the floodplain require a floodplain development permit. All construction, including structures that are exempt from a building permit, must follow the guidelines within KCC 14.08. Structures may be subject to mandatory flood insurance purchase requirements. (SC)
WATER MITIGATION/ METERING	No comments. (SC)
AIRPORT	No comments. (JS)

Please contact Kittitas County Public Works (509) 962-7523 with any questions.