



To Protect and Promote the Health and the Environment of the People of Kittitas County

May 30, 2024

Zach Torrance-Smith
Kittitas County Community Development Services
411 N. Ruby Street
Ellensburg, WA 98926

Dear Zach,

The following are Public Health's comments on the SP-24-00008 Frosty Pines II.

1. At least one soil log per lot not already served by on-site septic must be provided before final plat approval.
2. A signed, notarized and recorded two party shared well users' agreement between the lots to be served by the individual well and well log for the existing well must be submitted to the Health Department for review.
3. Establish a one-hundred-foot protection zone around each existing and proposed well site.

These requirements must be met before final plat signature can be obtained.

Sincerely,

A handwritten signature in black ink, appearing to read 'Dan Suggs', is written over a light blue horizontal line.

Dan Suggs, B.S
Environmental Health Specialist II
509-962-7024

