



**STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY**

Central Region Office

1250 West Alder St., Union Gap, WA 98903-0009 • 509-575-2490

May 10, 2023

Jeremiah Cromie
Kittitas County
411 N. Ruby St., Suite 2
Ellensburg, WA 98926

RE: 202301967, VA-23-00003

Dear Jeremiah Cromie:

Thank you for the opportunity to comment on the Mitigated Notice of Application for the Sparks Park Variance, Easton Truck Stop. We have reviewed the application and have the following comment.

WATER RESOURCES

Dust Control from a Well

If you plan to use water for dust suppression at your project site, be sure that you have a legal right. In Washington State, prospective water users must obtain authorization from the Department of Ecology before diverting surface water or withdrawing ground water, with one exception. Ground water withdrawals of up to 5,000 gallons per day used for single or group domestic supply, up to 5,000 gallons per day used for industrial purposes, stock watering, and for the irrigation of up to one-half acre of non-commercial lawn and garden are exempt from the permitting process. Water use under the RCW 90.44.050 exemption establishes a water right that is subject to the same privileges, restrictions, laws and regulations as a water right permit or certificate obtained directly from Ecology. Temporary permits may be obtainable in a short time-period. The concern of Water Resources is for existing water rights. In some instances water may need to be obtained from a different area and hauled in or from an existing water right holder.

If you have any questions or would like to respond to these Water Resources comments, please contact Christopher Kossik at (509) 379-1826 or email at christopher.kossik@ecy.wa.gov.

TOXICS CLEANUP

Installation of new underground storage tanks must meet the requirements of the state underground storage tank regulations (Chapter 173-360A WAC). All new tanks and piping must have double-wall

Jeremiah Cromie
May 10, 2023
Page 2 of 2

construction and be interstitially monitored for releases. Copies of these regulations and required forms are available from the Department of Ecology by calling (360) 407-7270 or toll-free in state 1-800-826-7716.

<http://app.leg.wa.gov/WAC/default.aspx?cite=173-360A>

<https://ecology.wa.gov/Regulations-Permits/Guidance-technical-assistance/Underground-Storage-Tank-checklists-forms>

A notice of intent to install tanks must be filed with Ecology at least 30 days prior to installation. Within 30 days after coming into service, the tanks must be registered with the Department of Revenue's Business License Service on a state notification form. <https://dor.wa.gov/sites/default/files/2022-02/700041.pdf>

<https://apps.ecology.wa.gov/publications/SummaryPages/ECY02095.html>

The supervisor on-site during the installation must be licensed by passing an exam administered by the International Code Council. www.iccsafe.org

New tanks and any connected piping must be protected from corrosion by either a cathodic protection system, or by being constructed or coated with a non-corrosive material such as fiberglass. An acceptable method of leak detection must be employed, and the tanks must be equipped with spill prevention and overfill protection equipment.

Stage I vapor recovery equipment is required on all new gasoline dispensing facilities with a total gasoline nominal storage capacity greater than 10,000 gallons.

Other local permits may be required for the installation or permanent closure of underground storage tanks. Contact your local fire marshal and planning department to procure any permits required by county or other local jurisdictions.

Please contact Mike Webb, Underground Storage Tank Inspector, at (509) 406-6572 or email mike.webb@ecy.wa.gov, for further information or to schedule your initial sampling.

Sincerely,



Lucila Cornejo
SEPA Coordinator,
Central Regional Office
(509) 208-4590
crosepacoordinator@ecy.wa.gov